

PHPP 概论


演讲者:
叶士杰

德国被动房屋讲师
德国被动房屋设计师
英国BREEAM AP
沃科绿建筑工程师

PHPP介绍: 内容

- 介绍
- 使用 PHPP: 排序
- 边界状况
- 非透明建筑材质
- 窗户
- 通风
- 热需求和热负荷
- 生活热水需求和热损
- 电力需求
- 一次性能源需求
- 夏季时节应用

概要: PHPP 2007



被动式房屋准则

通风系统 $\geq 75\%$ 热回收效率
最高用电要求 0.45 Wh/m^3

对于热的防护:
 $U \leq 0.15 \text{ W/(m}^2\text{K)}$
 $U_w \leq 0.8 \text{ W/(m}^2\text{K)}$
避免热桥发生

外部新鲜空气

排风

三层玻


$U_g \leq 0.8 \text{ W/(m}^2\text{K)}$
g值 50 - 55 %

回风


出风

气密性
: $n_{50} \leq 0.6 / \text{h}$

暖通需求	$\leq 15 \text{ kWh/(m}^2\text{a)}$
或 建筑供暖负荷	$\leq 10 \text{ W/m}^2$
有效制冷需求	$\leq 15 \text{ kWh/(m}^2\text{a)}$
一次性能源需求	$\leq 120 \text{ kWh/(m}^2\text{a)}$
建筑气密性	$\leq 0.6 / \text{h}$
超过 25°C 温度的时间频率	$\leq 10\%$



热传递




传递:

热平衡外围护的面积 * U值 * 温度校正系数 * 热流时

$$Q_T = A * U * f_t * G_t$$

通风换气




通风换气:

风量 * 等效换气 * 热容量(空气) * 热度时

$$Q_v = V * n_{\text{equiv.}} * c_p \rho * G_t$$

太阳辐射热得



太阳辐射热得:

折减系数 * g-值 * 窗户面积 * 总辐射

$$Q_s = r * g * A * G$$

内部热得




内部热得:

供暖期时间长度 * 具体室内热得 * 实际居住面积

$$Q_i = t_{\text{Heat}} * q_i * A_{\text{TFA}}$$

暖通需求，依照整年度的计算过程



暖通需求:

剩余差额 = 热传递 + 通风换气 - η^* (太阳辐射热 + 室内热得)

$$Q_H = Q_T + Q_V - \eta^*(Q_S + Q_I)$$

实际住宅案例 Freundorfer, Oberaudorf



Freundorfer住宅: 立面




南向立面



西向立面




东向立面



北向立面


Freundorfer 单一家庭住宅: 剖面

边界能量平衡= 外部尺寸




Freundorfer 单一家庭住宅: 立面 - 1

位置图: 使用位置号码



南向立面



东向立面

位置图范例:



- 红色数字为立面和屋顶
- 蓝色 F+数字为窗户和门
- 和额外的热桥

Freundorfer 单一家庭住宅: 立面 - 2

位置图: 使用位置号码


位置图范例:

- 红色数字为立面和屋顶
- 蓝色 F+数字为窗户和门
- 和额外的热桥




Freundorfer 单一家庭住宅: 一楼平面图

Treated floor area (TFA) = 实际居住面积



输入外墙结构

2	Exterior Wall Plastered					
Assembly No. Building Assembly Description						
Heat Transfer Resistance [m ² K/W]						
					interior R _{si} : 0,13	
					exterior R _{se} : 0,04	
Area Section 1	λ [W/(mK)]	Area Section 2 (optional)	λ [W/(mK)]	Area Section 3 (optional)	λ [W/(mK)]	Total Width Thickness [mm]
1.	Gypsum Plasterboard	0,800				12
2.	Flax Insulation	0,040	Wooden Post 40mm, hor. Dis	0,130		60
3.	OSB Board	0,170				15
4.	Cellulose, Insulation	0,040		Wooden Post	0,130	340
5.	Wood Fibre Insulation Board	0,050				60
6.	Plaster	0,600				5
7.						
8.						
Percentage of Sec. 2					6,3%	
Percentage of Sec. 3					7,2%	
					Total	49,2 cm
U-Value:					0,097	W/(m ² K)



外墙组成 Exterior Wall Plastered

- 12.5 mm Gypsum Plasterboard, λ=0.80 W/mK
- 60 mm Flax Insulation, λ=0,40 W/mK, 6.3% Wood
- 15 mm OSB, λ=0.17 W/mK
- 340 mm Cellulose, λ=0,04 W/mK, 7.2% Wood
- 60 mm Wood Fibre Insulation Board, λ=0.050 W/mK
- 5 mm Plaster, λ=0.80 W/mK

PHPP: 面积数据输入

Area Input																
Area Nr.	Building Element Description	Group Nr.	Assigned to Group	Quantity	x (a [m]	x	b [m]	+	User-Determined [m²]	-	User Subtraction [m²]	-	Subtraction Window Areas [m²]) =	Area [m²]
	Treated Floor Area	1	Treated Floor Area		x (x		+		-		-) =	0,0
	North Windows	2	North Windows													4,1
	East Windows	3	East Windows													8,2
	South Windows	4	South Windows													28,4
	West Windows	5	West Windows													6,5
	Horizontal Windows	6	Horizontal Windows													0,0
	Exterior Door	7	Exterior Door	1	x (1,15	x	2,25	+		-		-) =	2,6
1					x (x		+		-		-	0,0) =	
2	EXW North Ground Floor planked	8	Exterior Wall - Ambient	1	x (13,77	x	2,86	+		-	2,59	-	4,1) =	32,7
3	EXW North First Floor plastered	8	Exterior Wall - Ambient	1	x (13,83	x	3,08	+		-		-	0,0) =	42,6
4	EXW South Ground Floor planked	8	Exterior Wall - Ambient	1	x (13,77	x	2,86	+		-		-	16,2) =	23,2
5	EXW South First Floor plastered	8	Exterior Wall - Ambient	1	x (13,83	x	3,08	+		-		-	12,2) =	30,4
6	EXW East Ground Floor planked	8	Exterior Wall - Ambient	1	x (8,40	x	2,86	+		-		-	5,2) =	18,9
7	EXW East First Floor plastered	8	Exterior Wall - Ambient	1	x (8,40	x	3,67	+		-		-	3,0) =	27,8
8	EXW West Ground Floor plastered	8	Exterior Wall - Ambient	1	x (8,40	x	2,86	+		-		-	3,5) =	20,5
9	EXW West First Floor plastered	8	Exterior Wall - Ambient	1	x (8,40	x	3,67	+		-		-	3,0) =	27,8
10					x (x		+		-		-	0,0) =	
11					x (x		+		-		-	0,0) =	
12					x (x		+		-		-	0,0) =	
13	Roof	10	Roof/Ceiling - Ambient	2	x (13,83	x	4,43	+		-		-	0,0) =	122,5
14	Cellar Floor Slap	11	Floor Slab	1	x (13,77	x	8,34	+		-		-	0,0) =	114,8
15					x (x		+		-		-	0,0) =	

Please complete in Windows worksheet only!



使用位置图的区域编号




分配所属的组别, 请参考
Summary rows 7-20

扣除窗户面积


(面积数据来自另一个工作表)




Freundorfer 单一家庭住宅的接合细部




屋檐Eaves :
 $\Psi = -0.025 \text{ W/(mK)}$




屋脊Ridge :
 $\Psi = -0.064 \text{ W/(mK)}$



二楼楼板
First floor slab :
 $\Psi = +0.018 \text{ W/(mK)}$



屋顶角Verge :
 $\Psi = -0.041 \text{ W/(mK)}$



墙基座Plinth :
 $\Psi = -0.039 \text{ W/(mK)}$


在"Area"工作表输入热桥值

Thermal Bridge Inputs												
Nr. of Thermal Bridge	Thermal Bridge Description	Group Nr.	Assigned to Group	Quantity	x (User Determined Length [m]	-	Subtraction User-Determined Length [m])=	Length l [m]	Input of Thermal Bridge Heat Loss Coefficient W/(mK)	ψ W/(mK)
1	EXW-Corner	15	Thermal Bridges Ambient	4	x (5,96	-)=	23,84	EXW-Corner	-0,065
2	EXW-Roof (Eaves	15	Thermal Bridges Ambient	1	x (46,21	-)=	46,21	EXW-Roof (Eaves, Verg	-0,041
3	EXW-Cellar Floor	16	Perimeter Thermal Bridge	1	x (44,48	-)=	44,48	EXW-Cellar Floor Slap	-0,039
4	Roof Ridge	15	Thermal Bridges Ambient	1	x (13,83	-)=	13,83	Roof Ridge	-0,064
5	INW-Roof	15	Thermal Bridges Ambient	1	x (37,00	-)=	37,00	INW-Roof	-0,001
6	EXW-INW	15	Thermal Bridges Ambient	1	x (39,00	-)=	39,00	EXW-INW	0,004
7	INW-Cellar Floor	15	Thermal Bridges Ambient	1	x (36,10	-)=	36,10	INW-Cellar Floor Slap	0,014
8	EXW-intermediat	15	Thermal Bridges Ambient	1	x (44,48	-	4,00)=	40,48	EXW-intermediat Floor	0,018
9	Window-Roller J	15	Thermal Bridges Ambient	2	x (1,60	-)=	3,20	Window-Roller Jalousie	0,015
10					x (-)=			




来自于底板的热损失


基于 ISO 13370 的计算




放置于表土的楼板
Floor slab on grade



架高的底板
suspended floor slab




有采暖的地下室
Heated Basement




无采暖的地下室
unheated basement

保温裙摆



练习: 评估窗户U-值



在质量和数量方面评估结果

评估窗户本身:

窗户 U_w 值**0.82 W/(m²K)**略高于**0.80 W/(m²K)**的门坎。

改善窗框或玻璃边缘的断热。透过降低 Ψ_g 至**0.033 W/(mK)**, 窗户U-值 U_w 则为**0.80 W/(m²K)**。

评估含安装的窗户:

窗户U-值(含安装) $U_{w, \text{install}}$ **0.89 W/(m²K)** 高于**0.85 W/(m²K)**的门坎, 故改善保温材并让其覆盖窗框或改善玻璃边缘的断热。

降低窗框安装的热桥 Ψ_f 至**0.010 W/(mK)**, $U_{w, \text{install}}$ 则可降低至**0.85 W/(m²K)**

或改善玻璃U-值 U_g 至**0.60 W/(m²K)**, $U_{w, \text{install}}$ 则可降低至**0.83 W/(m²K)**

WinTyp 工作表数据 (玻璃和窗框)

GLAZING ACCORDING TO CERTIFICATION

for frame types, go to row: 71

Assembly No.	Type Glazing	g-Value	U _g -Value W/(m ² K)
1	Schwabenglas	0,520	0,600
2			
3			
4			
45	iPlus 3 CE - INTERPANE	0,47	0,56
46	iPlus 3 CE - INTERPANE	0,47	0,66
47	GDG iplus 3S - Glas Dreisbusch	0,52	0,74
48	RX WARM 0,58 - Reflex d.o.o.	0,47	0,58
49	RX WARM 0,64 - Reflex d.o.o.	0,47	0,64

FRAME TYPE ACCORDING TO CERTIFICATION

for glazings, go to row: 2

Assembly No.	Type Frame	U _f -Value Frame W/(m ² K)	Frame Dimensions				Thermal Bridge	Thermal Bridge
			Width - Left m	Width - Right m	Width - Below m	Width - Above m	Ψ _{Spacer} W/(mK)	Ψ _{Installation} W/(mK)
1	Zwoa2Wood with Sash	0,97	0,118	0,118	0,118	0,118	0,040	0,023
2	Zwoa2Wood Fix	0,97	0,081	0,081	0,081	0,081	0,040	0,023
3								
4								
95	OPTIWIN - installation wood construction (OPTIWIN Zwoa2Holz)	0,97	0,122	0,122	0,115	0,122	0,028	-0,005

别忘记遮阳!

- 遮阳是一个决定性的因素
- 常见错误
- 优化潜力
- 透明的区域
- 范例: 外部墙面窗户的位置



Biburg/Alling, Arch. G. Vallentin
单一家庭被动房


遮阳的信息输入

Window Area Orientation	Global Radiation (Cardinal Points)	Shading	Dirt	Non-Perpendicular Incident Radiation	Glazing Fraction	g-Value	Reduction Factor for Solar Radiation
maximum:	kWh/(m ² a)	0,75	0,95	0,85			
North	151	0,39	0,95	0,85	0,669	0,52	0,21
East	296	0,80	0,95	0,85	0,745	0,52	0,48
South	559	0,72	0,95	0,85	0,707	0,52	0,41
West	291	0,64	0,95	0,85	0,749	0,52	0,39
Horizontal	425	0,75	0,95	0,85	0,000	0,00	0,00
Total or Average Value for All Windows.						0,52	0,40

窗户遮阳的设置


- 方法:每个窗户需要一个单独的遮阳设定
- 3种遮阳方式
 - 树木, 建筑物, 山群
 - 建筑物外部侧面
 - 出挑

基地配置图 – 来自群山的遮阳




500 m


水平遮阳





棱角造成的阴影 (水平线)




窗户侧墙面所造成的遮阳



出挑遮阳



PHPP: 遮阳设定




太阳光热的取得

$$Q_S = r * g * A_F * G$$

r: 窗框所占比例、遮阳、灰尘和辐射的入射角等会造成的衰减系数


g: 垂直太阳辐射穿过玻璃窗的总透射率

G: 在供暖时期天体的热辐射 (气候工作表)



Window Area Orientation	Global Radiation (Cardinal Points)	Shading	Dirt	Non-Perpendicular Incident Radiation	Glazing Fraction	g-Value	Reduction Factor for Solar Radiation
maximum:	kWh/(m²a)	0,75	0,95	0,85			
North	151	0,39	0,95	0,85	0,669	0,52	0,21
East	296	0,80	0,95	0,85	0,745	0,52	0,48
South	559	0,72	0,95	0,85	0,707	0,52	0,41
West	291	0,64	0,95	0,85	0,749	0,52	0,39
Horizontal	425	0,75	0,95	0,85	0,000	0,00	0,00
Total or Average Value for All Windows.						0,52	0,40

概念：送风和回风的对流通风准则



标注空气量

针对住宅建筑物进行验证和测试:

送风: **20 to 30 m³/小时/人** (e.g. according to DIN 1946-6)
传送给整个建筑物，而并非只是单独的房间

回风:	房间	空气流量
	厨房	60 m ³ /h
	浴室	40 m ³ /h
	厕所, 储藏室,...	20 m ³ /h

至少: **空气替换率 0.3**
(相对于整个公寓的面积和2.5米的室内高度)

范例:




3人居住公寓, 85 m² 客厅: 3 房间, 1 厨房, 1 浴室

新鲜空气要求: 3 人 x 30 m³/小时/人 = 90 m³/小时

空气回风要求: 60 + 40 = 100 m³/h

空气最小替换: 0.30 /h x 85 m² x 2.5 m = 64 m³/小时

一楼平面图



体积流量的通风计划

3. Distribution of the airflow volume flow rate

Nr.	Room (each valve individually)	Area A m ²	Clear Height h m	Room Volume A x h m ³	Air Volume Flow Rate			Air Change Rate n 1/h	Type of Flow-Off Vent (door gap, grid in door leaf door frame, valve ...)
					V _{SU} m ³ /h	V _{EX} m ³ /h	V _{THROUGH} m ³ /h		
1	Ground Floor Entrance	5,59	2,50	14,0			15	1,07	door gap
2	Ground Floor Corridor	13,63	2,50	34,1			10	0,29	different
3	Ground Floor Stairs	0,00	2,50	0,0			10	#DIV/0!	different
4	Ground Floor Shower / Toilet	6,40	2,50	16,0		15		0,94	grid
5	Ground Floor Living room	18,27	2,50	45,7	30			0,66	door gap
6	Ground Floor Living room	12,62	2,50	31,5	15			0,48	door gap
7	Ground Floor Kitchen	13,71	2,50	34,3		45		1,31	door gap
8	Ground Floor Office / Guest Room	16,02	2,50	40,0	15			0,37	door frame
9	Ground Floor Technic	1,78	2,50	4,5		5		1,12	door gap
10	Ground Floor Storage	2,18	2,50	5,5		5		0,92	door gap
11	First Floor Room 1	15,57	2,50	38,9	15			0,39	door frame
12	First Floor Room 2	12,62	2,50	31,5	15			0,48	door frame
13	First Floor Room 3	15,16	2,50	37,9	15			0,40	door frame
14	First Floor Room 4	14,09	2,50	35,2	30			0,85	door frame
15	First Floor Corridor	10,83	2,50	27,1			75	2,77	different
16	First Floor Stairs	0,00	2,50	0,0			75	#DIV/0!	different
17	First Floor Storage	1,78	2,50	4,5		5		1,12	door gap
18	First Floor Toilet	2,18	2,50	5,5		15		2,75	door gap
19	First Floor Bathroom	8,27	2,50	20,7		35		1,69	grid
20	First Floor Dressing room	5,17	2,50	12,9		10		0,77	door gap
	sum:	175,86	---	439,65	135,0	135,0	---	0,31	

PHPP: 平均的空气替换率

Treated Floor Area A_{TFA}	m ²	176	(Areas worksheet)
Room Height h	m	2,5	(Annual Heat Demand worksheet)
Room Ventilation Volume ($A_{TFA} \cdot h$) = V_V	m ³	440	(Annual Heat Demand worksheet)

Ventilation System Design - Standard Operation

- Occupancy
- Number of Occupants
- Supply Air per Person
- Supply Air Requirement
- Extract Air Rooms
- Quantity
- Extract Air Requirement per Room
- Total Extract Air Requirement

m ² /P	35				
P	5,0				
m ³ /(P*h)	30				
m ³ /h	150				
Extract Air Rooms	Kitchen	Bathroom	Shower	WC	Other
Quantity	1	1	1	1	5
m ³ /h	60	40	20	20	12
m ³ /h	200				

房间的数量

通风系统必须能够供应: 多于30% 的设定通风量

Design Air Flow Rate (Maximum)

m ³ /h	200
-------------------	-----

Average Air Change Rate Calculation

Type of Operation	Daily Operation Duration h/d	Factors Referenced to Maximum	Air Flow Rate m ³ /h	Air Change Rate 1/h
Maximum		1,00	200	0,45
Standard	24,0	0,75	150	0,34
Basic		0,54	108	0,24
Minimum		0,40	80	0,18
<input checked="" type="checkbox"/> Residential Building		Average value 0,75	Average Air Flow Rate (m ³ /h) 150	Average Air Change Rate (1/h) 0,34


通风设备的平均空气替换率

外围护边界 – 设备安装




通风设备在外围护内

小心, 结露: 需要防潮层!



通风设备在外围护外面



照片+ 绘制:
Passive House Institute, Darmstadt

PHPP: 标注热回收效率

Effective Heat Recovery Efficiency of the Ventilation System with Heat Recovery

- Central unit within the thermal envelope.
- Central unit outside of the thermal envelope.

Efficiency of Heat Recovery	η_{HR}		0,78	Drexel & Weiss Aerosilent classic
Transmittance Supply Air Duct	Ψ	W/(mK)	0,340	Calculation see Secondary Calculation
Length Supply Air Duct		m	2	
Transmittance Extract Air Duct	Ψ	W/(mK)	0,340	Calculation see Secondary Calculation
Length Extract Air Duct		m	2	
Temperature of Mechanical Services Room (Enter only if the central unit is outside of the thermal envelope.)		°C	12	Room Temperature (°C) Av. Ambient Temp. Heating P. (°C) Av. Ground Temp (°C)

Effective Heat Recovery Efficiency $\eta_{HR,eff}$

77,3%

Effective Heat Recovery Efficiency Subsoil Heat Exchanger

SHX Efficiency	η^*_{SHX}	60%
Heat Recovery Efficiency SHX	η_{SHX}	20%

设备和建筑外围护结构之间的管道尽可能越短越好!

PHPP:风管的热传输值


Secondary Calculation:

Ψ -value Supply or Ambient Air Duct

Nominal Width	160	mm
Insul. Thickness:	60	mm
Reflective? Please mark with an "x"!		
<input type="checkbox"/>	Yes	
<input checked="" type="checkbox"/>	No	
Thermal Conductivity	0,035	W/(mK)
Nominal Air Flow Rate	150	m ³ /h
$\Delta\theta$	8	K
Interior Duct Diameter	0,160	m
Interior Diameter	0,160	m
Exterior Diameter	0,280	m
α -Interior	9,96	W/(m ² K)
α -Surface	5,74	W/(m ² K)
Ψ-value	0,340	W/(mK)
Surface Temperature Difference	1,081	K

保温材厚度

一般的宽度



PHPP暖气管道

Space Heat Distribution

- Length of Distribution Pipes
- Heat Loss Coefficient per m Pipe
- Temperature of the Room Through Which the Pipe:
- Design Flow Temperature
- Design System Heat Load
- Flow Temperature Control (check)
- Design Return Temperature
- Annual Heat Emission per m of Plumbing
- Possible Utilization Factor of Released Heat
- Annual Losses
- Specif. Losses
- Utilisation Factor of Space Heat Distribution**

L_H (Project)
 Ψ (Project)
 ϑ_X Mechanical Room
 ϑ_{dist} Flow, Design Value
 $P_{heating}$ (exist./calc.)
 $\vartheta_R = 0.714 * (\vartheta_{dist} - 20) + 20$
 $q^*_{HL} = \Psi (\vartheta_m - \vartheta_X) t_{Heating} * 0.024$
 η_G
 $Q_{HL} = L_H \cdot q^*_{HL} \cdot (1 - \eta_G)$
 $q_{HL} = \Sigma Q_{HL} / A_{TFA}$
 $h_{a,HL} = q_H / (q_H + q_{HL})$


Warm Region	Cold Region		Total	
	1	2		
24,00	6,00			m
0,134	0,134			W/(mK)
20	10,0			°C
55,0	55,0			°C
0,5	0,5			kW
j	j			
45,0	45,0			°C
20	26			Total 1,2,3 kWh/(m·a)
74%	0%			-
122	158	0	280	kWh/a
				kWh/(m²a)
			91%	-

输入:

- 出流+ 回流管道的长度
- 每米管道的热损失系数
- 出流温度/控制
- 热负荷

结果:

- 利用系数, 剩余热损失



PHPP: 家用热水需求和管循环

DHW: Standard Useful Heat

DHW Consumption per Person and Day (60 °C)
Average Cold Water Temperature of the Supply
DHW Non-Electric Wash and Dish

V_{DHW} (Project or Average Value 25 Litres/P/d)
 ϑ_{DW} Temperature of Drinking Water (10°)
(Electricity worksheet)

Useful Heat - DHW

Q_{DHW}

Specif. Useful Heat - DHW

$q_{DHW} = Q_{DHW} / A_{TFA}$

25,0	Litre/Person/d
7,5	°C
0	kWh/a
2779	kWh/a
	kWh/(m²a)

DHW Distribution and Storage

Length of Circulation Pipes (Flow + Return)
Heat Loss Coefficient per m Pipe
Temperature of the Room Through Which the Pipes
Design Flow Temperature
Daily circulation period of operation.
Design Return Temperature
Circulation period of operation per year
Annual Heat Released per m of Pipe
Possible Utilization Factor of Released Heat
Annual Heat Loss from Circulation Lines

L_{HS} (Project)
 Ψ (Project)
 ϑ_x Mechanical Room
 ϑ_{dist} Flow, Design Value
 td_{Circ} (Project)
 $\vartheta_R = 0.875 * (\vartheta_{dist} - 20) + 20$
 $t_{Circ} = 365 td_{Circ}$
 $q^*z = \Psi (\vartheta_m - \vartheta_x) t_{Circ}$
 $\eta_{GDHW} = t_{heating} / 365d * \eta_G$
 $Q_z = L_{HS} \cdot q^*z \cdot (1 - \eta_{GDHW})$


Warm Region	Cold Region		Total
33,8	6,0		m
0,134	0,134		W/m/K
20	10,0		°C
45,0	45,0		°C
6,0	6,0		h/d
42	42		°C
2190	2190		h/a
6,9	9,8		kWh/m/a
41,6%	0,0%		-
136	59		194 kWh/a

输入:

- 每人家用热水的数量, 冷水温度
- 热水管 + 循环管的长度
- 每米管道的热损失系数
- 出流温度/ 运作时间


结果:

- 利用系数, 剩余热损失



PHPP: 个别管道和锅炉的热损失

Total Length of Individual Pipes	L_U (Project)		21,17			m
Exterior Pipe Diameter	d_{U_Pipe} (Project)		0,020			m
Heat Loss Per Tap Opening	$q_{Individual}$	$= (c_{pH2O} V_{H2O} + c_{pMat} V_{Mat}) (\theta_{dist} - \theta_x)$	0,1527			kWh/tap open
Occupancy Coefficient	n_{Tap}	$= n_{Pers} \cdot 3 \cdot 365 / n_{LU}$	5475			Tap openings
Annual Heat Loss	q_U	$= n_{Tap} \cdot q_{Individual}$	836,0			kWh/a
Possible Utilization Factor of Released Heat	η_{G_U}	$= t_{heating} / 8760 \cdot \eta_G$	41,6%			-
Annual Heat Loss of Individual Pipes	Q_U	$= q_U \cdot (1 - \eta_{G_U})$	488,2			488 kWh/a
Total 1,2,3						
Average Heat Released From Storage	P_s			32		W
Possible Utilization Factor of Released Heat	η_{G_s}	$= t_{heating} / 8760 \cdot \eta_G$		0,0%		
Annual Heat Losses from Storage	Q_s	$= P_s \cdot 8.760 \text{ kh} \cdot (1 - \eta_{G_s})$		280,3		280 kWh/a
Total 1,2,3						
Total Heat Losses of the DHW System	Q_{WL}	$= Q_z + Q_U + Q_s$				963 kWh/a
Specif. Losses of the DHW System	q_{WL}	$= Q_{WL} / A_{TFA}$				kWh/(m ² a)
Utilisation Factor DHW Distrib and Storage	$\eta_{a,WL}$	$= q_{DHW} / (q_{DHW} + q_{wv})$				74,3%
Total Heat Demand of DHW system	Q_{gDHW}	$= Q_{DHW} + Q_{WL}$				3742 kWh/a



PHPP: 太阳能热水供应

输入:

- 集热器类型的选择
- Aperture光圈
- 座向
- 选择储存的类型
- 储存的大小

结果:

- 预估满足家用热水需求的太阳系数
- 储存损失
- 图示说明每月平均值

HOT WATER PROVIDED BY SOLAR

Building: Building Type/Use:
 Location: Treated Floor Area A_{TFA}: m²

Solar Fraction with DHW Demand including Washing and Dish-Washing


Heat Demand DHW q_{DHW} kWh/a from DHW+Distribution worksheet
 Latitude: ° from Climate Data worksheet
 Selection of collector from list (see below): Selection: Improved Flat Plate Collector
 Solar Collector Area m²
 Deviation from North °
 Angle of Inclination from the Horizontal °
 Height of the Collector Field m
 Height of Horizon h_{Hor} m
 Horizontal Distance θ_{Hor} m
 Additional Reduction Factor Shading f_{Other} %
 Occupancy Persons
 Specific Collector Area m²/Pers

Estimated Solar Fraction of DHW Production

Solar Contribution to Useful Heat kWh/a kWh/(m²a)

Secondary Calculation of Storage Losses

Selection of DHW storage from list (see below): Selection: Stratified Solar Storage with DHW Heat Exchanger
 Total Storage Volume litre
 Volume Standby Part (above) litre
 Volume Solar Part (below) litre
 Specific Heat Losses Storage (total) W/K
 Typical Temperature DHW °C
 Room Temperature °C
 Storage Heat Losses (Standby Part Only) W
 Total Storage Heat Losses W



PHPP 电力

Column Nr.	1	2	3	4	5	6	7	8	8a	9	10	11	12	13	14
Application	Used ? (1/0)	Within the Thermal Envelope? (1/0)	Norm Demand	Utilization Factor	Frequency	Reference Quantity	Useful Energy (kWh/a)	Electric Fraction	Non-Electric Fraction	Electricity Demand (kWh/a)	Additional Demand	Marginal Performance Ratio	Solar Fraction	Non-Electric Demand (kWh/a)	Primary Energy-Demand (kWh/a)
<div style="display: flex; justify-content: space-between;"> <div> <p># Households: 1 HH</p> <p>Persons: 5,0 P</p> <p>Living Area: 176 m²</p> <p>Annual Heat Deman: 15 kWh/(m²a)</p> </div> <div> <p>Solar Fraction of DHW Wash&Dish</p> <p>Marginal Performance Ratio DHW: 125%</p> <p>Marginal Performance Ratio Heating: 125%</p> </div> <div> <p>Prim. Energy Factors: Electricity 2,7 kWh/kWh</p> <p>Natural Gas 1,1 kWh/kWh</p> <p>Energy Carrier for Space Heating/DHW: </p> </div> </div>															
Dishwashing	1	1	1,20 kWh/Use	1,00	65 /((P*a)	5,0 P =	390	100%	0%	390					1053
Cold Water Connect															
Clothes Washing	1	1	1,10 kWh/Use	1,00	57 /((P*a)	5,0 P =	314	100%	0%	314					846
Cold Water Connection															
Clothes Drying with:	1	1	3,50 kWh/Use	0,88	57 /((P*a)	5,0 P =	873	100%	0%	873					2357
Condensation Dryer				0,60			0		0%	0				0	0
Energy Consumed by Evaporation	0	1	3,13 kWh/Use	0,60	57 /((P*a)	5,0 P =	0		####	0				0	0
Refrigerating	1	1	0,78 kWh/d	1,00	365 d/a	1 HH =	285	100%		285					769
Freezing	1	1	0,88 kWh/d	1,00	365 d/a	1 HH =	321	100%		321					867
or Combined Unit	0	1	1,00 kWh/d	1,00	365 d/a	1 HH =	0	100%		0					0
Cooking with:	1	1	0,25 kWh/Use	1,00	500 /((P*a)	5,0 P =	625	100%		625					1688
Electricity									0%					0	0
Lighting	1	1	60 W	1,00	2,90 kh/(P*a)	5,0 P =	870	100%		870					2349
Consumer Electronics	1	1	80 W	1,00	0,55 kh/(P*a)	5,0 P =	220	100%		220					594
Small Appliances, etc	1	1	50 kWh	1,00	1,00 /((P*a)	5,0 P =	250	100%		250					675
Total Aux. Electricity							965			965					2605
Other:							0			0					0
							0			0					0
							0			0					0
Total							5112 kWh			5112 kWh				0 kWh	13803 kWh
Specific Demand										29,1 kWh/(m²a)				0,0 kWh/(m²a)	78,5 kWh/(m²a)
Recommended Maximum Value										18					50

PHPP 辅助电力

1	Living Area	176	m ²		2	Heating Period	205	d		3	Air Volume	440	m ³		4	Dwelling Units	1	HH		5	Enclosed Volume	769	m ³	
				Operation Vent. System Winter	4,91	kh/a					Primary Energy Factor - Electricity				2,7	kWh/kWh								
				Operation Vent. System Summer	3,85	kh/a					Annual Space Heat Demand				15	kWh/(m ² a)								
				Air Change Rate	0,34	h ⁻¹					Boiler Rated Power				10	kW								
				Defrosting HX from		°C					DHW System Heat Demand				3742	kWh/a								
												Design Flow Temperature				55	°C							

Column Nr.	1	2	3	4	5	6	7	8	9	10	11
Application	Used ? (1/0)	Within the Thermal Envelope? (1/0)	Norm Demand	Utilization Factor	Period of Operation	Reference Size	Electricity Demand (kWh/a)	Available as Interior Heat	Used During Time Period (kWh/a)	Internal Heat Source (W)	Primary Energy Demand (kWh/a)
Ventilation System											
Winter Ventilation	1	0	0,40 Wh/m ³	* 0,34 h ⁻¹	* 4,9 kh/a	* 439,653 m ³	= 295	considered in heat recovery efficiency			795
Summer Ventilation	1	0	0,40 Wh/m ³	* 0,34 h ⁻¹	* 3,9 kh/a	* 439,653 m ³	= 231	no summer contribution to IHG			624
Defroster HX	0	0	0 W	* 1,00	* 0,2 kh/a	* 1	= 0	* 1,0	/ 4,91	= 0	0
Heating System											
Controlled/Uncontrolled (1/0)											
Enter the Rated Power of the Pump											
Circulation Pump	1	0	40 W	* 0,8	* 4,9 kh/a	* 1	= 149	* 1,0	/ 4,91	= 0	402
Boiler Electricity Consumption at 30% Load											
Aux. Energy - Heat. Boiler	1	0	45 W	* 1,00	* 0,00 kh/a	* 1	= 0	* 1,0	/ 4,91	= 0	0
DHW system											
Enter Average Power Consumption of Pump											
Circulation Pump	1	0	29 W	* 1,00	* 5,0 kh/a	* 1	= 144	* 0,6	/ 8,76	= 0	390
Enter the Rated Power of the Pump											
Storage Load Pump DHW	1	0	59 W	* 1,00	* 0,4 kh/a	* 1	= 22	* 1,0	/ 4,91	= 0	59
Boiler Electricity Consumption at 100% Load											
DHW Boiler Aux. Energy	1	0	136 W	* 1,00	* 0,0 kh/a	* 1	= 0	* 1,0	/ 4,91	= 0	0
Enter the Rated Power of the Solar DHW Pump											
Solar Aux Electricity	1	1	42 W	* 1,00	* 1,8 kh/a	* 1	= 74	* 0,6	/ 8,76	= 5	200
Misc. Aux. Electricity											
Misc. Aux. Electricity	1	0	50 kWh/a	* 1,00	* 1,0	* 1 HH	= 50	* 1,0	/ 8,76	= 0	135
Total							965			5	2605
Specific Demand kWh/(m ² a) Divide by Living Area:							5,5				14,8

PHPP – “Boiler”工作表

选择锅炉类型

输入:

- 输出
- 位置
- 性能数据

结果:

- 收益损失率被转移到“PE-value”的工作表

Passive House Planning EFFICIENCY OF HEAT GENERATION (GAS, OIL, WOOD)

Building	Sonnen-Passivhaus Freundorfer	Building Type/Use	Einfamilienhaus	
Location	Oberbayern Voralpenland	Treated Floor Area A_{TFL}	176 m ²	
Covered Fraction of Space Heat Demand	(PE Value worksheet)		100%	
Space Heat Demand + Distribution Losses	$Q_{H+Q_{HL}}$ (DHW+Distribution)		2972 kWh	
Solar Fraction for Space Heat	$\eta_{Solar, H}$ (Separate Calculation)			
Effective Annual Heat Demand	$Q_{H, eff} = Q_{H+Q_{HL}} \cdot (1 - \eta_{Solar, H})$		2972 kWh	
Space Heat Demand without Distribution Losses	Q_H (Annual Heat Demand)		2942 kWh	
Covered Fraction of DHW Demand	(PE Value worksheet)		100%	
Total Heat Demand of DHW system	Q_{DHW} (DHW+Distribution)		3742 kWh	
Solar Fraction for DHW	$\eta_{Solar, DHW}$ (SolarDHW worksheet)		86%	
Effective DHW Demand	$Q_{DHW, eff} = Q_{DHW} \cdot (1 - \eta_{Solar, DHW})$		524 kWh	
Boiler Type	(Project)	Wood Log Burning (Direct and Indirect Release of Heat)		
Primary Energy Factor	(Data worksheet)	0,2 kWh/kWh		
CO ₂ -Emissions Factor (CO ₂ -Equivalent)		50 g/kWh		
Useful Heat Provided	Q_{Use}	3496 kWh/a		
Max. Heating Power Required for Heating the Building	P_{BH} (Heating Load worksheet)	2,34 kW		
Length of the Heating Period	t_{HP}	2945 h		
Length of DHW Heating Period	t_{DHW}	8760 h		
Use characteristic values entered (check if appropriate)?		<input checked="" type="checkbox"/>		
Design Output	$P_{NOM, rated}$ (Rating Plate)	10 kW	15 kW	10
Installation of Boiler (Outdoor: 0, Indoor: 1)		1	0	1
Input Values (Oil and Gas Boiler)				
Boiler Efficiency at 30% Load	$\eta_{30\%}$ (Manufacturer)			
Boiler Efficiency at Nominal Output	$\eta_{100\%}$ (Manufacturer)			
Standby Heat Loss Boiler at 70 °C	$Q_{S, 70}$ (Manufacturer)			
Average Return Temperature Measured at 30% Load	$\bar{\theta}_{30\%}$ (Manufacturer)			
Input Values (Biomass Heat Generator)				
Efficiency of Heat Generator in Basic Cycle	η_{02} (Manufacturer)	68%	68%	
Efficiency of Heat Generator in Constant Operation	η_{10} (Manufacturer)	80%	70%	80%
Average Fraction of Heat Output Released to Heating Circuit	$z_{HC, H}$ (Manufacturer)	0,7	0,4	0,7
Temperature Difference Betw. Power-On and Power-Off	$\Delta\theta$ (Manufacturer)	30 K	30	
For Interior Installations: Area of Mechanical Room	$A_{M, int}$ (Project)	42 m ²	35 m ²	42
Useful Heat Output per Basic Cycle	$Q_{H, 02}$ (Manufacturer)	10,0	15,0	10,0
Average Power Output of the Heat Generator	$Q_{H, H}$ (Manufacturer)	6,0 kW	10,0	6,0
Utilisation Factor Heat Generator Heating Run	$\eta_{H, G, K} = \eta_{H, G}$	57%		
Utilisation Factor Heat Generator DHW Run	$\eta_{DHW, G, K} = \eta_{100\%} \cdot \eta_{DHW}$	56%		
Utilisation Factor Heat Generator DHW & Heating	$\eta_{G, K}$	57%		

PHPP – “Compact”工作表 (附有排风热泵)

选择紧凑型类型:

- 根据PHI证书的数据库将数据输入于相同的工作表

结果:

- 性能比值被转换到“PE-Value”工作表

COMPACT UNIT WITH EXHAUST AIR HEAT PUMP

Selection of Compact Unit (Data Inputs from Row 173): compact heat pump unit type 1

Measured Values from Laboratory Test

Ventilation

Effective Heat Recovery Efficiency η_{eff} (Test Stand) 78 %

Electric Efficiency (Test Stand) 0,40 Wh/m³

Heating

	Test Point 1	Test Point 2	Test Point 3	Test Point 4	
Ambient Air Temperature T_{amb}	-2,0	2,0	7,0		°C
Measured Thermal Power Heat Pump Heating $P_{\text{HP,Heating}}$	1,03	1,18	1,34		kW
Measured COP Heating $\text{COP}_{\text{Heating}}$	2,22	2,73	3,07		-

DHW

	Test Point 1	Test Point 2	Test Point 3	Test Point 4	
Ambient Air Temperature T_{amb}	-2,0	2,0	7,0	20,0	°C
Measured Thermal Power DHW Storage Heating-Up $P_{\text{DHW,Heating-Up}}$	0,92	1,13	1,28	1,49	kW
Measured Thermal Power DHW Storage Reload $P_{\text{DHW,Reload}}$	0,88	1,10	1,28	1,41	kW
Measured COP DHW Storage Heating-Up $\text{COP}_{\text{DHW,Heating-Up}}$	2,51	2,93	3,26	3,47	-
Measured COP DHW Storage Reload $\text{COP}_{\text{DHW,Reload}}$	2,08	2,39	2,71	2,71	-

Standby (Inputs required only if different from storage reload)

	Test Point 1	Test Point 2	Test Point 3	Test Point 4	
Ambient Air Temperature T_{amb}					°C
Measured Thermal Power Heat Pump Standby $P_{\text{HP,Standby}}$					kW
Measured COP Standby $\text{COP}_{\text{Standby}}$					-

Specific Heat Loss Storage incl. Connections $U^* A_{\text{storage}}$ (Test Stand) 1,60 WK

Average Storage Temperature in Standby Mode $T_{\text{DHW,Standby}}$ (Test Stand) 47 °C

Performance Ratio of Heat Generator, DHW & Space Heating

Annual Coefficient of Performance

COP

66%

1,5

PHPP 区域热水供暖系统

输入:

- 太阳对于暖通覆盖的贡献比例。
- 选择区域热水供暖的类型
- 热传输站的性能比例


结果:

- 家用热水的PE-需求

EFFICIENCY OF DISTRICT HEATING STATIONS

Building:	Sonnen-Passivhaus Freundorfer	Building Type/Use:	Einfamilienhaus	
Location:	Oberbayern Voralpenland	Treated Floor Area A_{TFA} :	176	m ²
Covered Fraction of Space Heat Demand		(PE Value worksheet)	100%	
Annual Heat Demand kWh/a		Q_H (DHW+Distribution)	2972	kWh
Solar Fraction for Space Heat		$\eta_{Solar, H}$ (Separate Calculation)		
Effective Annual Heat Demand	$Q_{H,wf} = Q_H * (1 - \eta_{Solar, H})$		2972	kWh
Covered Fraction of DHW Demand		(PE Value worksheet)	100%	
DHW Demand		Q_{DHW} (DHW+Distribution)	3742	kWh
Solar Fraction for DHW		$\eta_{Solar, DHW}$ (SolarDHW worksheet)	86%	
Effective DHW Demand	$Q_{DHW,wf} = Q_{DHW} * (1 - \eta_{Solar, DHW})$		524	kWh
Heat Source			Gas CGS 35% PHC	
Primary Energy Factor		(Data worksheet)	1,1	kWh/kWh
CO ₂ -Emissions factor (CO ₂ -Equivalent)		(Data worksheet)	130	g/kWh
Utilisation Factor Heat Transfer Station		$\eta_{a, HX}$	107%	
Final Energy Demand Heat Generation	$Q_{final} = Q_{Use} * e_{a, DH}$		kWh/a	kWh/(m ² a)
			3267	18,6
Annual Primary Energy Demand			3594	20,4
			kg/a	kg/(m ² a)
Annual CO₂-Equivalent Emissions			425	2,4

被动式房屋夏季时分



PHPP – “Summer”工作表

输入:

- 具体的储热容量: 轻质和重结构的总和
- 舒适限制:
25 or 26° C
- 白天经由窗户的机械式通风或单纯窗户通风
- 在夜间经由窗户的机械式通风或单纯窗户通风

结果:

- 过热的频率
- 由于太阳热负荷所造成的每日温度波动

Passive House Planning
SUMMER

Climate: Interior Temperature: °C
 Building: Building Type/Use:
 Location: Treated Floor Area A_{TFA} : m²
 Spec. Capacity: Wh/K per m² TFA
 Overheating Limit: °C

Building Element	Temperature Zone	Area	U-Value	Red. Factor $f_{R,summer}$	$H_{T,trans}$ Heat Conductance
1. Exterior Wall - Ambie	A	223,8	0,098	1,00	21,8
2. Exterior Wall - Group	B			1,00	11,8
3. Roof/Ceiling - Ambie	A	122,5	0,096	1,00	11,8
4. Floor Slab	B	114,8	0,091	1,00	10,4
5.	A			1,00	
6.	A			1,00	
7.	X			0,75	
8. Windows	A	47,3	0,863	1,00	40,8
9. Exterior Door	A	2,6	0,650	1,00	1,7
10. Exterior TB (length/	A	239,7	-0,012	1,00	-2,9
11. Perimeter TB (length	P	44,5	-0,039	1,00	-1,7
12. Ground TB (length/m)	B			1,00	

Exterior Thermal Transmittance, $H_{T,e}$: Wh/K
 Ground Thermal Transmittance, $H_{T,g}$: Wh/K

Heat Recovery Efficiency: Effective Air Volume V_e : m³ Clear Room Height: m
 SHK Efficiency: = m³

Summer Ventilation (continuous ventilation to provide sufficient indoor air quality)
 Air Change Rate by Natural (Windows & Leaks) or Exhaust-Only Mechanical Ventilation, Summer: 1/h
 Mechanical Ventilation Summer: 1/h with HR (check if applicable)

Energetically Effective Airchange Rate n_{eff} : + * (1 -) = 1/h

Ventilation Transm. Ambient $H_{V,e}$: m³ * 1/h * Wh/(m³·K) = Wh/K
 Ventilation Transm. Ground $H_{V,g}$: m³ * 1/h * Wh/(m³·K) = Wh/K

Additional Summer Ventilation for Cooling Temperature Amplitude Summer: K
 Select: Window Night Ventilation, Manual Mechanical, Automatically Controlled Ventilation
 Corresponding Air Change Rate: 1/h (for window ventilation: at 1 K temperature difference indoor - outdoor)
 Minimum Acceptable Indoor Temperature: °C

Orientation of the Area	Angle Factor	Shading Factor	Dist	g-Value (see: radiation)	Area	Portion of Glazing	Aperture
1 North	0,9	0,43	0,95	0,32	4,1	67%	0,5
2 East	0,9	0,56	0,95	0,32	0,2	75%	1,5
3 South	0,9	0,53	0,95	0,32	20,4	71%	4,7
4 West	0,9	0,41	0,95	0,32	0,5	75%	0,8
5 Horizontal	0,9	1,00	0,95	0,00	0,0	0%	0,0
6 Sum. Aperture Area					0,9		0,9

Solar Aperture: Total: m²

Internal Heat Gains Q_i : W/m² * m² = W Wh/m²

Frequency of Overheating $h_{22,3h}$: at the overheating limit $\theta_{max} = 25$ °C
 If the "frequency over 25°C" exceeds 10%, additional measures to protect against summer heat waves are necessary.

Daily Temperature Swing due to Solar Load: Wh/m² * 1/h / (Wh/(m²·K) * m²) = K

“Summer” 工作表

SUMMER

Climate:	Garmisch-Partenkirchen
Building:	Sonnen-Passivhaus Freundorfer
Location:	Oberbayern Voralpenland

Interior Temperature:	20	°C
Building Type/Use:	Einfamilienhaus	
Treated Floor Area A_{TFA} :	175,9	m ²

Spec. Capacity: 84 Wh/K pro m² TFA

Overheating Limit: 25 °C

Building Element	Temperature Zone	Area m ²	U-Value W/(m ² K)	Red. Factor $f_{T,Summer}$	H_{Summer} Heat Conductance
1, Exterior Wall - Ambient	A	223,8	0,098	1,00	21,9
2, Exterior Wall - Ground	B			1,00	
3, Roof/Ceiling - Ambient	A	122,5	0,096	1,00	11,8
4, Floor Slab	B	114,8	0,091	1,00	10,4
5,	A			1,00	
6,	A			1,00	
7,	X			0,75	
8, Windows	A	47,3	0,863	1,00	40,8
9, Exterior Door	A	2,6	0,650	1,00	1,7
10, Exterior TB (length/m)	A	239,7	-0,012	1,00	-2,9
11, Perimeter TB (length/m)	P	44,5	-0,039	1,00	-1,7
12, Ground TB (length/m)	B			1,00	

Exterior Thermal Transmittance, $H_{T,e}$

Ground Thermal Transmittance, $H_{T,g}$

73,2	W/K
8,7	W/K

Frequency of Overheating $h_{\vartheta \geq \vartheta_{max}}$ **0,0%**

at the overheating limit $\vartheta_{max} = 25\text{ °C}$

If the "frequency over 25°C" exceeds 10%, additional measures to protect against summer heat waves are necessary.

“Summer” 工作表

Summer Ventilation continuous ventilation to provide sufficient indoor air quality

Air Change Rate by Natural (Windows & Leakages) or Exhaust-Only Mechanical Ventilation, Summer: 1/h

Mechanical Ventilation Summer: 1/h with HR (check if applicable)

$$\text{Energetically Effective Airchange Rate } n_v = n_{L,nat} + n_{V,system} * (1 - \Phi_{HR}) + n_{V,Rest} = 0,273 + 0,300 * (1 - 0,000) + 0,000 = 0,573 \text{ 1/h}$$

Ventilation Transm. Ambient $H_{V,e}$	V_V m³	*	$n_{V,eq,frac}$ 1/h	*	C_{Air} Wh/(m³K)	*	=	<input type="text" value="57,0"/> W/K
Ventilation Transm. Ground $H_{V,g}$	<input type="text" value="440"/>	*	<input type="text" value="0,393"/>	*	<input type="text" value="0,33"/>	*	=	<input type="text" value="26,1"/> W/K

Additional Summer Ventilation for Cooling Temperature Amplitude Summer K

Select: Window Night Ventilation, Manual Corresponding Air Change Rate 1/h
 Mechanical, Automatically Controlled Ventilation (for window ventilation: at 1 K temperature difference indoor - outdoor)

Minimum Acceptable Indoor Temperature °C

Orientation of the Area	Angle Factor Summer	Shading Factor Summer	Dirt	g-Value (perp. radiation)	Area m²	Portion of Glazing	Aperture m²
1. North	0,9	* <input type="text" value="0,43"/>	* <input type="text" value="0,95"/>	* <input type="text" value="0,52"/>	* <input type="text" value="4,1"/>	* <input type="text" value="67%"/>	= <input type="text" value="0,5"/>
2. East	0,9	* <input type="text" value="0,56"/>	* <input type="text" value="0,95"/>	* <input type="text" value="0,52"/>	* <input type="text" value="8,2"/>	* <input type="text" value="75%"/>	= <input type="text" value="1,5"/>
3. South	0,9	* <input type="text" value="0,53"/>	* <input type="text" value="0,95"/>	* <input type="text" value="0,52"/>	* <input type="text" value="28,4"/>	* <input type="text" value="71%"/>	= <input type="text" value="4,7"/>
4. West	0,9	* <input type="text" value="0,41"/>	* <input type="text" value="0,95"/>	* <input type="text" value="0,52"/>	* <input type="text" value="6,5"/>	* <input type="text" value="75%"/>	= <input type="text" value="0,9"/>
5. Horizontal	0,9	* <input type="text" value="1,00"/>	* <input type="text" value="0,95"/>	* <input type="text" value="0,00"/>	* <input type="text" value="0,0"/>	* <input type="text" value="0%"/>	= <input type="text" value="0,0"/>
6. Sum Opaque Areas							<input type="text" value="0,9"/>

Solar Aperture

Total m²/m²

“Summer” 工作表

Internal Heat Gains Q_i

$$\begin{array}{ccccccc} \text{Specif. Power } q_i & & A_{TFA} & & & & \\ \text{W/m}^2 & & \text{m}^2 & & \text{W} & & \text{W/m}^2 \\ \hline & 2,10 & * & 176 & = & 369 & 2,1 \end{array}$$

Frequency of Overheating $h_{g \geq g_{max}}$ **0,4%** at the overheating limit $g_{max} = 25 \text{ }^\circ\text{C}$

If the "frequency over 25°C" exceeds 10%, additional measures to protect against summer heat waves are necessary.

Caution: Large daily temperature swing. Calculation of overheating frequency is not reliable.

$$\begin{array}{ccccccc} \text{Solar Load} & & \text{Spec. Capacity} & & A_{TFA} & & \\ \text{kWh/d} & & \text{Wh/(m}^2\text{K)} & & \text{m}^2 & & \\ \hline \text{Daily Temperature Swing due to Solar Load} & 40,2 & * & 1000 & / (& 60 & * & 176 &) = & \mathbf{3,8} & \text{K} \end{array}$$

10%的过热频率意味着超过10%以上的时间温度达到25-28 (被认为是“正常”)

20%的过热频率意味着超过20%以上的时间温度达到25-32 (被认为是不能忍受)

(使用隐藏在78至149行的建筑模拟来计算)


“SummVent”的工作表

SUMMER VENTILATION

Building:	Sonnen-Passivhaus Freundorfer
Location:	Oberbayern Voralpenland

Building Type/Use:	Einfamilien
Building Volume	440

Description	Day GRF	Day FIF	Night	
Fraction of Opening Duration	13%	50%	50%	
Climate Boundary Conditions				
Temperature Diff Interior - Exterior	4	4	1	
Wind Velocity	1	1	0	
Window Group 1				
Quantity	4	4	1	
Clear Width	0,78	0,78	0,99	
Clear Height	2,12	2,12	2,12	
Tilting Windows?	x	x	x	
Opening Width (for tilting windows)	0,060	0,060	0,060	
Window Group 2 (Cross Ventilation)				
Quantity			4	
Clear Width			0,78	
Clear Height			2,12	
Tilting Windows?			x	
Opening Width (for Tilting Windows)			0,060	
Difference in Height to Window 1			2,80	
Single-Sided Ventilation 1 - Airflow Volume	191	191	0	20
Single-Sided Ventilation 2 - Airflow Volume	0	0	0	93
Cross Ventilation Airflow Volume	191	191	0	113
Contribution to Air Change Rate	0,06	0,22	0,00	0,13



Summary of Summer Ventilation Distribution

Description	Ventilation Type	Daily Average Air Change Rate
Day GRF		0,06 1/h
Day FIF		0,22 1/h
Night		0,13 1/h

给“Summer”工作表

气候数据: 选择

CLIMATE DATA

Building: **Sonnen-Passivhaus Freundorfer**

Standard/Regional Climate: Select here. Use Regional Data Yes

Regional Climate Data: Climate Building Garmisch-Partenkirchen H_T 205 d/a

Select Region Here: Germany Chosen Method for Annual Heat Demand: Monthly Method G_t 93 kWh/a

Monthly Data: Garmisch-Partenkirchen H_{North} 151 kWh/(m²a)

Annual Data: No H_{East} 296 kWh/(m²a)


Use Annual Climate Data Set No H_{South} 559 kWh/(m²a)

Select regional climate here: Garmisch-Partenkirchen H_{West} 291 kWh/(m²a)

Results: Annual Heat Demand 15,3 kWh/(m²a) $H_{Horizontal}$ 425 kWh/(m²a)

Heat Load 13,3 W/m²

Transfer to Annual Method



	Month	1	2	3	4	5	6	7	8	9	10	11	12	Heating Load		
		Days	31	28	31	30	31	30	31	31	30	31	30	31	Weather 1	Weather 2
Parameters for PHPP Calculated Ground Temperatures:	Garmisch-Partenkirchen	Latitude:	47,5	Longitude ° East	11,1	Altitude m	719			Daily Temperat ure Swing Summer (K)	10,1	Radiation Data:	kWh/(m ² * month)	Radiation: W/m ²		
Phase Shift Months	Ambient Temp	-3,0	-1,3	1,9	6,1	10,8	13,8	15,8	15,0	12,2	7,4	1,7	-2,7	-10,6	-7,8	23,0
2,00	North	14	20	35	45	56	59	60	48	34	25	14	12	20	10	100
Damping	East	29	42	65	79	95	91	99	91	67	52	30	25	40	15	210
-1,05	South	78	85	96	86	83	76	86	92	94	99	76	66	80	20	190
Depth m	West	30	42	64	75	86	87	97	87	68	51	30	25	35	15	210
3,32	Global	39	58	97	123	151	152	168	143	104	74	42	31	50	20	350
Shift of Average Temperature K	Dew Point	-4,8	-3,7	-0,9	2,7	6,7	10,2	11,7	11,5	9,1	4,9	0,2	-3,3			
1,60	Sky Temp	-13,8	-12,2	-8,0	-2,7	2,9	7,7	9,7	9,5	6,2	0,4	-6,3	-11,5			12,8
	Ground Temp	8,9	8,8	8,8	9,0	9,3	9,6	10,5	10,6	9,9	9,7	9,4	9,1	8,8	8,8	10,6

气候数据输入: 各自的气候数据

Annual Method (Name)

- ° C
- kWh/(m²*month)
- kWh/(m²*month)
- kWh/(m²*month)
- kWh/(m²*month)
- kWh/(m²*month)
- ° C
- ° C
- ° C
- kWh/(m²*month)
- kWh/(m²*month)
- kWh/(m²*month)
- kWh/(m²*month)
- kWh/(m²*month)
- ° C
- ° C

Month	Jan	Feb	Mar
Example	Latitude:	50,2	Longitude ° East
Ambient Temp	0,9	2	5,3
North	9,0	15,0	23,0
East	14,0	21,0	31,0
South	30,0	33,0	39,0
West	14,0	19,0	30,0
Global	23,0	34,0	52,0
Dew Point	0,3	-0,9	1,5
Sky Temp	-9,0	-8,6	-4,7
Data1	Latitude:		Longitude ° East
Ambient Temp			
North			
East			
South			
West			
Global			
Dew Point			
Sky Temp			

输入每月的外部空气温度和辐射数据

■ 输入数据组的名称